

Hidrofor seçim tablosu / Water Pressure Booster Selection Table													
Daire Sayısı / House Quantity	1-6	7-13	14-23	24-31	32-39	40-47	48-64	65-74	75-83	84-92	93-122	123-150	151-190
Debi / Flow Q. (m ³ /h)	2	3	5	7	9	11	13	15	17	19	21	25	30-35
Kat Sayısı / Floor Quantity	Önerilen Hidrofor / Recommended Water Pressure Booster												
	İşletme Basınç / Operating Pressure Hm (m)												
0-2	•205-6 TB	•205-6 TB	•205-6 TB	•205-6 TB	•205-12 TB	•212-5 TB	•212-5 TB	•212-5 TB	•216-4 TB	•216-4 TB	•216-4 TB	•216-5 TB	•225-4 TB
3-5	•205-6 TB	•205-6 TB	•205-6 TB	•205-6 TB	•206-6 TB	•212-5 TB	•212-5 TB	•212-5 TB	•216-4 TB	•216-4 TB	•216-5 TB	•216-7 TB	•225-4 TB
6-7	•205-8 TB	•205-8 TB	•205-8 TB	•206-6 TB	•206-6 TB	•212-5 TB	•212-5 TB	•212-5 TB	•216-5 TB	•216-5 TB	•216-7 TB	•212-5 TB	•225-4 TB
8-10	•205-8 TB	•205-8 TB	•205-8 TB	•206-6 TB	•206-8 TB	•212-7 TB	•212-7 TB	•216-5 TB	•216-7 TB	•216-7 TB	•216-7 TB	•225-4 TB	•225-6 TB
11-13	•205-12 TB	•205-12 TB	•205-12 TB	•206-8 TB	•205-12 TB	•212-7 TB	•212-7 TB	•212-10 TB	•216-7 TB	•216-7 TB	•212-7 TB	•212-7 TB	•225-8 TB
14-15	•205-12 TB	•205-12 TB	•205-12 TB	•206-11 TB	•205-12 TB	•212-10 TB	•212-10 TB	•216-7 TB	•216-7 TB	•216-7 TB	•212-7 TB	•212-7 TB	•225-8 TB
16-18	•205-12 TB	•205-12 TB	•205-12 TB	•206-11 TB	•205-12 TB	•212-10 TB	•212-10 TB	•216-7 TB	•216-7 TB	•216-7 TB	•212-10 TB	•212-10 TB	•225-8 TB
19-21	•206-11 TB	•206-11 TB	•206-11 TB	•206-11 TB	•205-12 TB	•212-10 TB	•212-10 TB	•216-7 TB	•216-7 TB	•216-7 TB	•212-10 TB	•212-10 TB	•225-8 TB
22-24	•206-11 TB	•206-11 TB	•206-11 TB	•206-11 TB	•205-12 TB	•212-10 TB	•212-10 TB	•216-7 TB	•216-7 TB	•216-7 TB	•212-10 TB	•212-10 TB	•225-8 TB
25-26	•206-11 TB	•206-11 TB	•206-11 TB	•206-11 TB	•205-12 TB	•212-10 TB	•212-10 TB	•216-7 TB	•216-7 TB	•216-7 TB	•212-10 TB	•212-10 TB	•225-8 TB
27-29	•206-11 TB	•206-11 TB	•206-11 TB	•206-11 TB	•205-12 TB	•212-10 TB	•212-10 TB	•216-7 TB	•216-7 TB	•216-7 TB	•212-10 TB	•212-10 TB	•225-8 TB
30	•206-11 TB	•206-11 TB	•206-11 TB	•206-11 TB	•205-12 TB	•212-10 TB	•212-10 TB	•216-7 TB	•216-7 TB	•216-7 TB	•212-10 TB	•212-10 TB	•225-8 TB

• Tablo da yer alan daire sayıları ve kat sayıları karşılık gelen daireler 1.80 litre/gün/hirey faz alınarak hesaplanmıştır